

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Ref- 1/2025/091

Dated: 03/12/2025

It is certified that an inspection team headed by Sanjay Singh & Vandana Singh

(Name of Officers with designation) from U.P.JAL.KAL.NIGAM.LTD PHED

inspected the Shree Chitaranjan Convent School, Shree Ashoortilal, Bairya Nagar

(Name & Address of the school) on 03/12/2025.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. W.A.R./J.N.P./053/2025-26... dated.. 01/12/2025

of Water Analysis Report Dist-Jaunpur PHED Lab) certified that

the Shree Chitaranjan Convent School. (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ... One Year

Signature with Seal: ... अधिकारी अधिकारी
Name : खण्ड कार्यालय
Designation : उत्तर प्रदेश जल निगम (ग्रामीण)
Name & Address of the Office / Department : जानपुर

To
The Manager.....

(Name & Address of the Institution)

Shree Chitaranjan Convent School, Shree
Ashoortilal, Bairya Nagar near Court Hospital, Moolchahar, Jaunpur

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Water Analysis Report, District-Jaunpur,

UTTAR PRADESH

Rept No	439		Date	01/12/2025		Page No	01
Customer Details							
Office Name and Address		SHREE CHITARANJAN CONVENT SCHOOL, SHREE ASHARFI LAL BAIDYA NAGAR, NEAR GOVT. HOSPITAL, MARIAHU, JAUNPUR, U.P.					
Ref Letter No.		WAR/JNP/053/2025-26					
Basic details of sample							
District		JAUNPUR		Tehsil		MARIAHU	
Gram Panchayat		-		Village		-	
Habitation		MARIAHU		Location		SHREE ASHARFI LAL BAIDYA NAGAR, NEAR GOVT. HOSPITAL, MARIAHU, JAUNPUR, U.P.	
Water Source		R O Water		Sample No.		Sample 5	
Quality of Sample		1000ml (Normal)		Date of S.C.		01/12/2025	
Receiving Date		01/12/2025		S. Collector		Mr. SANJAY PATHAK	
Sample Depositor		MR. DILEEP KUMAR JAISWAL					
Analysis Start Date		01/12/2025		Analysis Completion Date		01/12/2025	
Technical Data of Analysis							
SR	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis		
			Acceptable Limit	Permissible Limit			
1	2	3	4	5	6		
1	pH	6.45	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 1983:2021(Electrometric Method)		
2	Turbidity (NTU)	0.45	1.00	5.00	IS 3025 (Part 10): 1984:2021(Nephelometer Method)		
3	TDS. Mg/1	321	500	2000	IS 3025 (Part 16): 1984:2021(Gravimetric Method)		
4	Chloride (as Cl), mg/1	11	250	1000	IS 3025 (Part 32): 1988:2021(Titration Method)		
5	Total Alkalinity (as Na ₂ CO ₃), mg/1	179	200	600	IS 3025 (Part 23): 1986:2021(Titration Method)		
6	Total Hardness (as CaCO ₃), mg/1	94	200	600	IS 3025 (Part 21): 2009:2021(Titration Method)		
7	Calcium (as Ca), mg/1	15.9	75	200	IS 3025 (Part 40): 2019		
8	Magnesium (as Mg), mg/1	14.6	30	100	IS 3025 (Part 46): 2019		
9	Nitrate (as NO ₃), mg/1	4	45	No Relaxation	APHA 23rd Ed 2017, 4500-NO ₃ (B.Ultraviolet Spectrophotometric Screening Method)		
10	Fluoride (as F), mg/1	0.358	1.00	1.5	APHA 23rd Ed 2017, 4500-F (C. Ion Selection Electrode Method)		
11	Iron (as Fe), mg/1	1.00	1.00	No Relaxation	APHA 23rd Ed 2017, 3500-Fe (B Phenanthroline Method)		
12	Residual Chlorine	0.2	NA	0.2	IS 3025 (Part 26): 2021		
13	Total Coliform (MPN/100mL)	0	NA	0.0	IS 1622		

Note-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test result reported in this certificate is valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepare by

Lab Technician

Authorized Signatory

Quality/Technical Manager